


Crossing and Designated House Moving Corridor Routes

Minimum Vertical Clearance for Crossings

House Moving Route	24 feet
Non-House Moving Route	22 feet
Parallel Aerial Lines	18 feet

If Minimum aeral clearances cannot be met cables shall be buried to meet State standards. Vertical clearance is measured from the highest point of the roadway to the cable.



Produced January 30, 2015 By Ramsey County Public Works GIS